

CERTIFICATE

Issued to:
Applicant:
Fabricación de Material Eléctrico, S.A.
C/Vapor 12-14 (Poligono Industrial La Ferreria)
08110 Montcada I Reixac, Spain

Product : Plugs, 2 pole
Trade name(s) : FME
Type(s)/model(s) : 1001 and 1001-N

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard IEC 60884-1:2002, IEC 60884-1:2002/A1:2006, IEC 60884-1:2002/A2:2013, UNE 20315-1-1:2017 and UNE 20315-1-2:2017
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 6057594
- the licensee is registered with the number 43117


DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.


This certificate is issued on 19 March 2020 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 31-113049

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



K Xu
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

| | |
|----------------------|---|
| Product | : Plugs, 2 pole |
| Trade name(s) | : FME |
| Type(s)/model(s) | : 1001 and 1001-N |
| Rated current | : 10 A |
| Rated voltage | : 250 V~ |
| Degree of protection | : IP20 |
| Earthing | : Without earthing-contacts |
| Design | : Rewirable, with solid pins, with pillar terminals |
| Standard sheet | : ESC 10b of UNE 20315-1-2 |
| Certification mark | : Complies with the requirements |
| Description | : Body of thermoplastic |

TESTS**Test requirements**

IEC 60884-1:2002
IEC 60884-1:2002/A1:2006
IEC 60884-1:2002/A2:2013
UNE 20315-1-1:2017
UNE 20315-1-2:2017

Test result

The test results are laid down in DEKRA test file 606433300.

Additional information

The list of components is laid down at test report 6064333.50.

Conclusion

The examination proved that all requirements were met.

Factory location

The factory location is registered with the number 42848.